

ADVERTISEMENT FOR BIDS

TOWN OF SPRINGPORT FIRE LANE 16 WATER LINE PROJECT

In accordance with Section 103 of Article 5-A of the General Municipal Law, sealed Bids for the supply of:

- A. 1,160 LF of 4" diameter DR-18 PVC Pipe suitable for potable water service. Pipe to be in 20' lengths and meet AWWA C900, with gasketed joints; Blue Brute C900 or equal. 4.80" outer diameter.
- B. 4" DR-18 PVC fittings for above pipe:
 - a. 22.5 degree elbow – Qty: 3
 - b. 45 degree elbow – Qty: 2
 - c. 4" to 2" reducing coupling – Qty 1
- C. Tapping sleeve for 8" PVC to 4" PVC – Qty: 1
- D. Curb Stops – 1", Qty: 11. Cast brass with O ring seals, compression type, Mueller H-15209, Mark II, or equal.
- E. Curb boxes with rods – by Buffalo or equal, 2.5" with SST stationary shutoff rod, ring and pin. 38"-66" extension range. Qty – 11.
- F. Corporation Stops – 1", Qty: 11. Cast brass with O ring seals, compression type, Mueller H-15008 or equal.
- G. Service pipes: 1" copper tubing, Type K meeting ASTM B88. Qty: 200 linear feet.
- H. Tapping saddles – double bolt full circle stainless steel saddles for 4" DR-18 PVC pipe. With full rubber gasket, not o-ring type. Cascade CSC2, Smith Blair 372, or approved equal. Qty: 11.
- I. Valve for 4" PVC Pipe, Qty: 1. Ductile iron, by Kennedy or equal, complying with AWWA C509, resilient wedge type, non-rising stem, square nut, with mechanical end joints for connection to 4" PVC pipe.
- J. Valve for 2" PVC Pipe, Qty: 1. Ductile iron, by Kennedy or equal, complying with AWWA C509, resilient wedge type, non-rising stem, square nut, with mechanical end joints for connection to 2" PVC pipe.
- K. Valve box for 4" valve – 2 piece adjustable valve box for 38"-66" extension range, 5.25" in diameter, cover marked "WATER", by Clow F-2454 or Bibby Ste-Croix, or equal. Qty: 1.
- L. Valve box for 2" valve – 2 piece adjustable valve box for 38"-66" extension range, 5.25" in diameter, cover marked "WATER", by Clow F-2454 or Bibby Ste-Croix, or equal. Qty: 1.
- M. 2" Blow-off Hydrant. Qty: 1. Frost free self-draining blow-off hydrant for 5'6" bury depth. MainGuard Model #77 by EJ Prescott, or approved equal. With 2.5" NST discharge nozzle, traffic breakaway design, locking cover with hasp for padlock, brass working parts, 2" female iron pipe inlet connection.
- N. Restrained coupling to connect 2" PVC pipe to Blow-Off hydrant. Qty: 1
- O. One (1) fire hydrant assembly, Kennedy type K81-D, with 6" guard valve, size for 5' water line bury depth, including 8x6 mechanical anchor tee to connect to existing 8" PVC pipe, including the mechanical connectors to attach the anchor tee to the 8: PVC line, one (1) 6" anchor fitting between valve and hydrant (18" minimum laying length),

plus one (1) Two-Part Valve Box to match valve provided, cast iron, made by Ford or Mueller, two-piece screw type, with lid inscribed with "WATER"; Hydrant to have two (2) 2 ½" nozzles and one (1) Storz connection.

Please send sealed bid labeled "Fire Lane 16 Water Line Project Materials Bid" to the Town of Springport Clerk at the Town office at: 859 State Route 326, Cayuga, NY 13034. Bids must be received by the Town Clerk before 11 AM on Friday May 31, 2024, at which time the Bids received will be publicly opened and read. Bids price must be clearly shown on the Bid Form, available for the Town Clerk.

All materials supplied are to be delivered to the project site at the intersection of Fire Lane 16 and Route 90 in Springport. State your proposed delivery date on the bid form. Delivery date will be considered along with price in selecting the winning bidder.

Sealed Bids will be received for this single sub-contract. Bids shall be on a lump sum basis.

The Town reserves the right to reject any or all bids, or to waive any informalities, or to make an award to other than the low bidder. It further reserves the right to limit the amount of the award. The Town does not discriminate on the basis of handicapped status in admission or access to, or treatment or employment in, its programs and activities.

No Pre-Bid Conference is scheduled. Any questions should be addressed to the Town contact, Tim Carpenter, P.E., TCarpenter@mrbgroup.com. Cell phone 315 350 8125.

No sales tax is to be charged for materials or labor for the project. The winning bidder will be supplied with a tax exempt certificate for the project.

Owner: Town of Springport
By: David Schenck, Supervisor
Dated: May 20, 2024

BID FORM -FIRE LANE 16

To: Town of Springport
859 Route 326
Cayuga, New York 13034

Project: Fire Lane 16 Project - Contract #1 – Material Supply and Delivery.

1. Lump Sum Price if all materials are Made in USA:

Written in numbers only: _____

Proposed Delivery Date: _____

2. Lump Sum Price if foreign sourced materials are allowed:

Written in numbers only: _____

Proposed Delivery Date: _____

- a. This bid shall remain valid for a period of forty-five (45) days from the date of bid.
b. Bidder signing below certifies that the prices in the bid have been arrived at independently without collusion, consultation, communication or agreement with any other bidder or with any competitor.

Bidder Signature

Bidder Printed Name

Bidder Company Name

Date

Telephone

I acknowledge receipt of the following Addenda:

Addenda # _____ Dated: _____

Addenda # _____ Dated: _____

Prepared By:
Town of Springport, NY

Bid Form-1